

Salisbury Township, Lehigh County
Private BMP Annual Inspection Form
DRY BIOFILTRATION SWALE / LEVEL SPREADER

Inspection Date: _____
Address: _____
Owner: _____ Contact: _____
Phone: _____ Email: _____
Maintenance Contractor: Yes No HOA: Yes No
Contractor Name: _____
Contractor Address: _____
Phone: _____ Email: _____

INSPECTION INSTRUCTIONS:

- Each BMP requires a separate inspection form.
- A photo of each BMP is required with the inspection form.
- Before and after photos for BMPs requiring maintenance.
- Complete the checklist that corresponds with the specific BMP.

CHECKLIST:			
Condition	Maintenance Required When:	Requires Maintenance Yes, No or N/A	Maintenance Performed Yes or No
GENERAL CONDITION			
Sediment accumulation on grass	Sediment depth exceeds 2 inches.		
Standing water	When water stands in the swale between storms and does not drain.		
Trash and debris accumulation	Trash and debris accumulated in bioswale.		
Erosion / scouring	Eroded or scoured areas due to flow channelization, or higher flows.		
Flow spreader	Flow spreader uneven or clogged so that flows are not uniformly distributed through entire filter width.		

Notes or Comments: _____

CHECKLIST:			
Condition	Requires Maintenance When:	Maintenance Needed Yes or No	Maintenance Performed Yes or No
Inlet / Outlet	Inlet / outlet areas clogged with sediment And or debris		
Trash and debris	Trash and debris accumulated in bioswale		
Erosion / scouring	Eroded or scoured swale bottom due to flow channelization, or higher flows.		

Notes or Comments: _____
