

**Resolution No. 03-2018-1606**

**BY THE BOARD OF COMMISSIONERS OF THE TOWNSHIP OF SALISBURY,  
LEHIGH COUNTY, PENNSYLVANIA, APPROVING THE FOLLOWING WAIVERS  
FOR THE GRADING PLAN FOR 1100 SOUTH 24<sup>TH</sup> STREET, ALLENTOWN,  
PENNSYLVANIA**

AND NOW this 22<sup>nd</sup> day of March, 2018, upon consideration of the attached plan, and the documentation in support thereof, the Township approves waivers for the Swain School's Grading Plan (plan dated December 21, 2017) for a soccer field being developed, with the following waivers from SALDO Stormwater Management provisions.

**NOW, THEREFORE, BE IT RESOLVED** that the following waivers for the Grading Plan for 1100 South 24<sup>th</sup> Street is hereby approved:


- a. A waiver from Section 1010.2.B.6, which sections requires fencing around the basin, granting the relief from this requirement except requiring the location of a fence between the basin and the field;
- b. A waiver from Section 1010.2.B.8, which requires the minimum basin bottom slope to be 2%, with a flat bottom being allowed; and
- c. A waiver from Section 1010.2.B.9, which requires the basin to be lined, with the Applicant indicating that since this is an infiltration drainage facility, they need to have no lining on the basin bottom so the water will infiltrate into the ground.


In addition, Developer shall be responsible for all reasonable costs incurred by the Township, including all reasonable legal and engineering fees incurred by the Township in conjunction with this plan approval process and shall be required to enter into a Best Management Practices Agreement with the Township.

**APPROVED AND ADOPTED** this 22<sup>nd</sup> day of March, 2018, at a regular public meeting in the Township of Salisbury, Lehigh County, Pennsylvania.

**ATTESTED:**

**TOWNSHIP OF SALISBURY  
(LEHIGH COUNTY, PENNSYLVANIA)**

  
Cathy Bonaskiewich,  
Township Manager

By:   
Robert Martucci, Jr., Chairman

